

## Report Back:

# ***Community, Apartment, Small Commercial: “Product Specs” in 3 years and beyond***

June 2, 2011

# Recall: Previously discussed metrics in 6-10 years



| <u>Category</u>                          | <u>ARPA-E's proposed</u>   | <u>Modifications</u>   |
|--|--|--|
| System rating                            | 200-500 kWe  | <b>10 -1000 kW</b>   |
| Electrical efficiency (@ ≥50% kW rating) | ≥60%   | <b>&gt; 55% for 50-200 kW Range</b>  |
| Part-load efficiency                     | ≥75% of max efficiency   | <b>&gt;75%-90% at 50% load</b>   |
| Emissions                                | EPA, CARB tier??   | <b>EPA Tier 4 - CARB should be used</b>  |
| Cost                                     | First cost: \$xxk installed, or \$1000/kW or LCOE: \$0.15/kWh over 7 years | <b>Aim for \$0.10/kWh. Installed cost 600-1500\$/kW</b>                              |
| Payback                                  | 2 – 3 yrs  | <b>&lt; 3 years</b>  |
| Unit volume @ price point                | 5,000  | <b>100-5000</b>  |
| Fuel type                                | NG, propane, biogas, fuel-flexible   | <b>Fuel flexible a bonus</b>   |
| Maintenance frequency                    | Once per year, maintenance <8 hr, \$xxx                                    | <b>Twice a year</b>  |
| Reliability                              | <1 unintentional outage per yr, <8 hrs 99.91%                              | <b>95%-99%</b>   |
| Lifetime                                 | >60,000 hrs before major overhaul or replacement                           | <b>Hard metric, prime mover needs &gt; 44 000 hours. Some want longer.</b>           |
| Electrical output type AC/DC, frequency  | AC = 60Hz, 120v<br>DC option??   | <b>208, 480 V as well</b>  |
| ...and more...                           |  | <b>Noise, 60 dB at 10 m<br/>Temperature -40 F to 125 F<br/>Turndown Ratio &gt; 3</b> |

## Key takeaways for the 3 year timeframe common to the 3 groups



1. A typical ARPA-E award is unlikely to be sufficient enough to build a 200 - 500 kW prototype
2. No technology agnostic 3 year metrics exist that will ensure reaching the 6-10 year metrics

## Other Takeaways



- Specific sub challenges that could be solicited for seeding projects
  - New materials enabling higher temperatures.
  - Better coatings.
  - Higher strength alloys.
  - Different engine cycles.
  - Isothermal or isoentropic compression for high efficiency ICEs
- Fast ramping is valuable for grid connected units.
- Cost assumptions should be provided to performers from ARPA-E to ensure an apples to apples comparison.
- There is an important distinction between modular and non-modular technologies – it is much easier to see how modular technologies (like fuel cells) will scale and thus easier to see how the costs will evolve.

# Group 1 key points



Two pathways for measuring progress during a 3 year program:

1. Technology specific metrics (Fuel cells, ICEs, microturbines, Stirling)
  1. Each area has their own specific current state of the art metrics
  2. Shared 6-10 year LCOE target (with efficiency, capex, opex inputs)
  3. Develop area-specific 3 year targets to enable the 6-10 year LCOE target
  4. These would be teased out during the breakout sessions on workshop day 2.
  
2. Open model – performers provide:
  1. The 6-10 year metrics (capex, efficiency, etc) that combine to provide a \$0.10/kWh product.
  2. A trajectory of what they will accomplish from year 0-6/10 to achieve the metrics at the end.
  3. What measurable results they will achieve within 3 years that will confirm their trajectory
    - ~10 kW prototype that achieves efficiency or cost improvement in a novel, promising way
    - Significant improvement/ modification to a baseline model.

## Group 2 key points



- 50 kW prototype is the right size to enable reliable properties when scaling up to 500 kW
- 52% efficiency
- Need a cost target for 3 years, but what? Halfway to \$1000 / kW?

## Group 3 key points



- Demonstrate efficiencies from 50-55% at any scale
- Demonstrate proforma calculation with \$0.15 / kWh or better and TRL 3 as key input data
- Typical prototyping costs \$10-20k / kW
  - \$1M prototype  $\rightarrow$   $\$1\text{M} / (\$20\text{k} / \text{kW}) = 50 \text{ kW}$ , maybe 2x smaller because of far-outness